

HVAC/R International, Inc.
TFC Series Line of CTI Certified Closed Circuit Cooling Towers
CTI Certification Validation Number 09-28-02
January 4, 2010 (Revision 0)

Standard Fan
For Markets With
1.00m³/h/T @ 37°C-32°C-28°C

Standard Fan
For Markets With
0.78m³/h/RT @ 37°C-32°C-27°C

TFC-60T

TFC-90RT

TFC-70T

TFC-100RT

TFC-80T

TFC-120RT

TFC-90T

TFC-135RT

TFC-100T

TFC-150RT

Footnotes:

1. Certification includes tower construction materials indicated by the suffixes -B, -E, and -S which are added to basic model numbers above.
 - B is for FRP casing, FRP basin and HDG mainframe and hardware.
 - E is for FRP casing, FRP basin and stainless steel mainframe and hardware
 - S is for stainless steel casing, basin, mainframe and hardware.
2. The basic model numbers above are for 50hz fan motor and the suffix /F is added for 60hz motor applications. For example, TFC-100T-B is for 50hz motor, TFC-100T-B/F is for 60hz motor.
3. Certification includes use of side, end, or bottom water inlet configuration.
4. Certification includes units with optional gear drive in place of standard belt drive.
5. Certification includes use of optional handrail and/or ladder cage.
6. Multiple cell models of the single cell models above are also available but not listed.