

Baltimore Aircoil Company, Inc.
Series 1500 Line of CTI Certified Cooling Towers
CTI Certification Validation Number 98-11-08
June 30, 2006 (Revision 6)

15146-HM	15162-HM	15200-JM	15214-JM	15296-KM	15310-KM
15146	15162	15200	15214	15296	15310
15160	15177	15227	15245	15325	15340
15176	15201	15250	15270	15350	15365
	15219		15282	15368	15385
					15425

Series 1500 Optional Accessories and Constructions – Certification Status

Option	Suffix Note 1	CTI Certified	Capacity Adjustment Required
Access Platform – External	none	Yes	No
Energy-Miser [®] Fan System	none	Yes	No
Low Sound Fan	Q	Yes	Note 2
“Whisper Quiet” Low Sound Fan	WQ	Yes	Note 3
Non-Standard Motor Size	M	Note 4	Yes, Note 4
Discharge Sound Attenuation	none	Yes	No
Unit not CTI Certified	X	No	Note 5

- Note: 1. Typically no suffix is used for an accessory or modification that does not affect capacity.
2. Low sound fans on Series 1500 Cooling Towers incur a capacity reduction of 3% relative to the same unit with a standard fan.
3. Whisper Quiet low sound fans on Series 1500 Cooling Towers use a high solidity fan running at reduced speed and incur a capacity reduction of 3 % relative to the same unit with a standard fan.
4. Units with non-standard motor sizes are certified only if they are listed in the Data of Record and sold at the revised capacity listed in the rating table.
5. This suffix is affixed to model numbers of units that are not CTI Certified, due either to application or product accessories or modifications.