

Baltimore Aircoil Company, Inc.
ACT Series Line of CTI Certified Cooling Towers
CTI Certification Validation Number 08-11-12
February 6, 2009 (Revision 1)

ACT-08161-G	ACT-08162-H	ACT-09172-J	ACT-09173-K
ACT-08161-H	ACT-08162-J	ACT-09172-K	ACT-09173-L
ACT-08161-J	ACT-08162-K	ACT-09172-L	ACT-09173-M
ACT-08161-K	ACT-08162-L	ACT-09172-M	ACT-09173-N
ACT-08161-L	ACT-08162-M	ACT-09172-N	ACT-09173-O
ACT-09174-L	ACT-10184-KM	ACT-10185-LM	ACT-11205-LM
ACT-09174-M	ACT-10184-LM	ACT-10185-MM	ACT-11205-MM
ACT-09174-N	ACT-10184-M	ACT-10185-N	ACT-11205-NM
ACT-09174-O	ACT-10184-N	ACT-10185-O	ACT-11205-O
ACT-09174-P	ACT-10184-O	ACT-10185-P	ACT-11205-P
	ACT-10184-P	ACT-10185-Q	ACT-11205-Q
	ACT-10184-Q	ACT-10185-R	ACT-11205-R
			ACT-11205-S
ACT-11206-MM	ACT-13216-MM	ACT-13217-NM	ACT-14237-OM
ACT-11206-NM	ACT-13216-NM	ACT-13217-OM	ACT-14237-P
ACT-11206-O	ACT-13216-O	ACT-13217-P	ACT-14237-Q
ACT-11206-P	ACT-13216-P	ACT-13217-Q	ACT-14237-R
ACT-11206-Q	ACT-13216-Q	ACT-13217-R	ACT-14237-S
ACT-11206-R	ACT-13216-R	ACT-13217-S	
ACT-11206-S	ACT-13216-S		

Optional Accessories and Constructions Table – Certification Status

Option	Suffix Note 1	CTI Certified	Capacity Adjustment Required
Low Sound Fan	Q	No	N.A.
Two Eliminator Sets	E	Yes	Yes, Note 2
Non-Standard Motor	M	Yes	Yes, Note 3
Not CTI Certified	X	No	Note 4

Notes:

1. Typically no suffix is used for an accessory or modification that does not affect capacity.
2. Two sets of eliminators incur a capacity reduction of 2% relative to the standard unit.
3. Units with non-standard motor sizes are certified only if they are listed in the Data of Record and sold at the revised capacity listed in the rating table.
4. This suffix is affixed to the model numbers of units that are not CTI Certified, due to application, product accessories, or modifications.