

Evapco, Inc.
LPT Line of CTI Certified Cooling Towers
CTI Certification Validation Number 05-13-04
January 3, 2005 (Revision 0)

LPT Series Basic Models

LPT 316	LPT 516	LPT 519	LPT 5112	LPT 819	LPT 8112
LPT 326	LPT 526	LPT 529	LPT 5212	LPT 829	LPT 8212
LPT 336	LPT 536	LPT 539	LPT 5312	LPT 839	LPT 8312
LPT 346	LPT 546	LPT 549	LPT 5412	LPT 849	LPT 8412
LPT 356	LPT 556	LPT 559	LPT 5512	LPT 859	LPT 8512
LPT 366	LPT 566	LPT 569	LPT 5612	LPT 869	LPT 8612
	LPT 576		LPT 5712	LPT 879	LPT 8712
	LPT 586				LPT 8812
	LPT 596				

Footnotes:

- 1 The following suffixes (I, D, H, F, L, U, LI, LD, LH and LF) are to be added to the basic numeric model designations listed above to indicate the tower configuration options that are also included in the CTI Certification.
 - I = Intake sound attenuation
 - D = Discharge sound attenuation
 - H = Tapered Discharge Hood
 - F = Full sound attenuation
 - L = One motor size smaller
 - U = Two motor sizes smaller
 - LI = Intake sound attenuation + One motor size smaller
 - LD = Discharge sound attenuation + One motor size smaller
 - LH = Tapered Discharge Hood + One motor size smaller
 - LF = Full sound attenuation + One motor size smaller
2. The optional tower configurations are unique in capacity. Selection software should be consulted for appropriate ratings of the tower configuration