



# COOLING TECHNOLOGY INSTITUTE

P. O. Box 7393, Houston, Texas 77273 • 2611 FM 1960 West, Suite A-101, Houston, Texas 77060  
Phone: 281.583.4087 • Fax: 281.537.1721 • email: [info@cti.org](mailto:info@cti.org) • <http://www.cti.org>

March 4, 2013

Liang Chi Industry Company, Ltd.  
No. 1, Sec. 3, Nan King East Road  
Taipei, Taiwan, R.O.C.

Subject: Voluntary Withdrawal of CTI Cooling Tower Thermal Certification  
Liang Chi Industry Company, Ltd.  
Series LC Line of Cross-flow, Induced-draft Cooling Towers

Gentlemen:

This is to acknowledge that the Liang Chi Industry Company, Ltd. line of Series LC cross-flow, induced-draft cooling towers intends to discontinue production and has voluntarily withdrawn the Series LC from the thermal performance certification program of the Cooling Technology Institute (CTI), as set forth in the CTI Certification Standard STD-201(11).

The Series LC line of CTI Certified cooling towers was assigned CTI Certification Validation Number 96-20-01. In accordance with the CTI STD-201(11), the manufacturer:

- (a) May use the Certification Label on all units from the certified line previously sold as CTI Certified, providing they ship within a 180 day period from the date of voluntary withdrawal.
- (b) Shall not use the Certification Label on any new units sold after the date of the voluntary withdrawal.
- (c) Shall remove all references to CTI Certification from the product brochures, published ratings, product drawings, and other literature pertaining to the withdrawn line within 120 days of the date of the voluntary withdrawal.

If there are any questions regarding the procedures listed above, please contact me.

Very truly yours,

Thomas E. Weast, P.E.  
CTI Certification Administrator