



# COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068  
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

**Shanghai Baofeng Machinery Manufacturing Co., Ltd.**  
**BTC Line of CTI Certified Closed-Circuit Cooling Towers**  
**CTI Certification Validation Number C49A-12R01**  
**September 21, 2016 (Revision 1)**

Standard Fan Models	Extended Stack Height Models
BTC-01S	BTC-01S(H)
BTC-02S	BTC-02S(H)
BTC-03S	BTC-03S(H)
BTC-04S	BTC-04S(H)
BTC-05S	BTC-05S(H)
BTC-06S	BTC-06S(H)
BTC-07S	BTC-07S(H)
BTC-08S	BTC-08S(H)

**Footnotes:**

1. CTI certification of thermal performance currently applies only to units with water as the process fluid and galvanized steel heat exchanger tubes.
2. Standard units have hot dipped galvanized structure and casing materials. Certification also includes alternate structure and casing materials.
3. Certification of models with suffix (H) established with extended fan stack height.
4. Certification includes access and maintenance options that do not affect thermal capacity.
5. Sample model number: BTC-03S.....  
Where: BTC = Product series designator  
-03 = Unit size designator  
S = Mixed flow configuration