



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Shanghai Liang Chi Cooling Equipment Co., Ltd..
LNCM Line of CTI Certified Cooling Towers
CTI Certification Validation Number C62B-16R00
July 28, 2016

LNCM-10	LNCM-65
LNCM-15	LNCM-80
LNCM-20	LNCM-100
LNCM-30	LNCM-125
LNCM-40	LNCM-150
LNCM-50	LNCM-175

Footnotes:

1. Multi-cell configurations of the primary single cell models are certified with an adjustment of the leg height of all of the cells to permit more open area for the remaining, unblocked, inlets of interior cells. This option limits the impact on airflow rate or capacity of the individual cells.
2. Certification includes galvanized steel plate or stainless steel plate structure materials and PVC or glass fiber reinforced casing materials.
3. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.

Certified Model Number Example: LNCM-150-C2

- LNCM – Line Designation
- 150 – Model Number (flow capacity at rated conditions, see selection table for details)
- C2 – Two cell arrangement of the primary certified model (capacity equals 2 times rated capacity)