



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Shanghai Liang Chi Cooling Equipment Co., Ltd..
LRS Line of CTI Certified Cooling Towers
CTI Certification Validation Number C62C-16R00
July 28, 2016

LRS-1001	LRS-5015
LRS-1002	LRS-5018
LRS-1003	LRS-5050
LRS-1011	LRS-8016
LRS-1020	LRS-8017
LRS-1030	LRS-8019
LRS-1050	LRS-9021
LRS-3020	LRS-9031
LRS-3030	LRS-9051
LRS-3050	LRS-9061

Footnotes:

1. Multiple cell configurations of the single cell models above are also available but not listed individually. Multi-cell configurations are end-wall to end-wall arrangements of the single cell designs which do not impact the air flow rate or capacity of the individual cells, and are included in the certification. See example model number below.
2. Certification includes galvanized steel or stainless steel structural materials and PVC or glass fiber reinforced casing materials.
3. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.

Certified Model Number Example: LRS-3030-C2

LRS – Line Designation

3030 – Model Number

C2 – Two cell arrangement of the primary certified model (capacity equals 2 times rated capacity)