

**Johnson Controls Air Conditioning and Refrigeration Fze.
York AT Line of CTI Certified Cooling Towers
CTI Certification Validation Number 99-13-01
July 15, 2011 (Revision 11)**

York AT Line – AT Models, USS/UAT Models, UT Models, and ATF Models

4 ft Nominal Width Units

14-64	14-66	14-69	14-612
14-74	14-76	14-79	14-712
14-84	14-86	14-89	14-812
14-94	14-96	14-99	14-912

8.5 ft Nominal Width Units

19-56L	26-517L	212-59L	19-111L	29-121L	217-111L	
19-56	26-517	212-59	19-111	29-121	217-111	
19-66	26-617	212-69	19-211	29-221L	217-211L	
19-76L	26-717L	212-79L	19-311L	29-221	217-211	
19-76	26-717	212-79	19-311	29-321	217-311	
19-86	26-817	212-89	19-411	29-421	217-411	
19-96L	26-917L	212-99L	19-511	29-521L	217-511L	
19-96	26-917	212-99	19-611L	29-521	217-511	
			19-611	29-621	217-611	
19-28L	28-217L	215-29L	19-711	29-721	217-711	
19-28	28-217	215-29	19-811	29-821	217-811	
19-38	28-317	215-39	19-911	29-921	217-911	
19-48	28-417	215-49				
19-58L	28-517L	215-59L	19-412L	29-024L	217-412L	39-336L
19-58	28-517	215-59	19-412	29-024	217-412	39-336
19-68	28-617	215-69	19-512L	29-124L	217-512L	39-436
19-78L	28-717L	215-79L	19-512	29-124	217-512	39-536
19-78	28-717	215-79	19-612	29-224L	217-612	39-636L
19-88	28-817	215-89	19-712L	29-224	217-712L	39-636
19-98	28-917	215-99	19-712	29-324	217-712	39-736
			19-812	29-424	217-812	39-836
19-59L	217-59L	29-318L	19-912	29-524	217-912	39-936L
19-59	217-59	29-318		29-624		39-936
19-69L	217-69L	29-418		29-724		
19-69	217-69	29-518L		29-824		
19-79	217-79	29-518		29-924		
19-89L	217-89L	29-618				
19-89	217-89	29-718	19-114L	29-228L	217-214L	39-242L
19-99	217-99	29-818L	19-114	29-228	217-214	39-242
		29-818	19-214L	29-328L	217-314L	39-342
		29-918	19-214	29-328	217-314	39-442L
			19-314	29-428	217-414	39-442
			19-414	29-528L	217-514L	39-542
			19-514L	29-528	217-514	39-642L
			19-514	29-628	217-614	39-642
			19-614	29-728	217-714	39-742
			19-714	29-828	217-814	39-842
			19-814	29-928	217-914	39-942
			19-914			

See Footnotes for Additional Information

**Johnson Controls Air Conditioning and Refrigeration Fze.
York AT Line of CTI Certified Cooling Towers
CTI Certification Validation Number 99-13-01
July 15, 2011 (Revision 11)**

York AT Line – AT Models, USS/UAT Models, UT Models, and ATF Models

12 ft Nominal Width Units

112-012L	212-024L	312-036L	424-024L	112-018L	212-036L	224-018L	312-054L	424-036L
112-012	212-024	312-036	424-024	112-018	212-036	224-018	312-054	424-036
112-112	212-124L	312-136L	424-124	112-118	212-136L	224-118	312-154L	424-136
112-212	212-124	312-136	424-224L	112-218L	212-136	224-218L	312-154	424-236L
112-312L	212-224	312-236	424-224	112-218	212-236L	224-218	312-254	424-236
112-312	212-324	312-336	424-324	112-318	212-236	224-318	312-354	424-336
112-412	212-424	312-436L	424-424	112-418L	212-336	224-418	312-454L	424-436
112-512L	212-524	312-436	424-524	112-418	212-436	224-518L	312-454	424-536L
112-512	212-624L	312-536	424-624L	112-518	212-536	224-518	312-554	424-536
112-612	212-624	312-636	424-624	112-618	212-636	224-618	312-654	424-636
112-712	212-724	312-736	424-724	112-718	212-736	224-718	312-754	424-736
112-812	212-824	312-836	424-824	112-818	212-836	224-818	312-854	424-836
112-912	212-924	312-936	424-924	112-918	212-936	224-918	312-954	424-936
112-314L	212-128L	312-042L	424-028L	112-520L		224-720L	312-260L	
112-314	212-128	312-042	424-028	112-520		224-720	312-260	
112-414L	212-228L	312-142L	424-128L	112-620L		224-820	312-360L	
112-414	212-228	312-142	424-128	112-620		224-920	312-360	
112-514L	212-328	312-242L	424-228	112-720L			312-460L	
112-514	212-428	312-242	424-328L	112-720			312-460	
112-614	212-528L	312-342	424-328	112-820			312-560	
112-714	212-528	312-442	424-428	112-920			312-660	
112-814	212-628	312-542	424-528				312-760	
112-914	212-728	312-642	424-628				312-860	
	212-828	312-742	424-728				312-960	
	212-928	312-842	424-828					
		312-942	424-928					

14 ft Nominal Width Units

114-0124L	214-0148L	228-0124L	314-0172L	428-0148L	114-526	214-552	314-578	228-526	428-552
114-0124	214-0148	228-0124	314-0172	428-0148	114-626	214-652	314-678	228-626	428-652
114-0224	214-0248	228-0224	314-0272	428-0248	114-726	214-752	314-778	228-726	428-752
114-0324L	214-0348	228-0324L	314-0372	428-0348	114-826	214-852	314-878	228-826	428-852
114-0324	214-0448L	228-0324	314-0472L	428-0448L	114-926	214-952	314-978	228-926	428-952
114-0424	214-0448	228-0424	314-0472	428-0448					
114-0524	214-0548	228-0524L	314-0572	428-0548					
114-0624L	214-0648L	228-0524	314-0672L	428-0648L					
114-0624	214-0648	228-0624	314-0672	428-0648					
114-0724	214-0748	228-0724	314-0772	428-0748					
114-0824	214-0848	228-0824	314-0872	428-0848					
114-0924	214-0948	228-0924	314-0972	428-0948					
114-1024	214-1048	228-1024	314-1072	428-1048					
114-1124	214-1148		314-1172	428-1148					
114-1224	214-1248		314-1272	428-1248					
114-1324			314-1372	428-1348					

See Footnotes for Additional Information

Johnson Controls Air Conditioning and Refrigeration Fze.
York AT Line of CTI Certified Cooling Towers
CTI Certification Validation Number 99-13-01
July 15, 2011 (Revision 11)

York AT Line – AT Models, USS/UAT Models, UT Models, and ATF Models
(Metric Sizes)

2.4 meter Nominal Width Units

18-49L	28-518L	216-49L	18-312L	28-524L	216-312L	38-236L
18-49	28-518	216-49	18-312	28-524	216-312	38-236
18-59L	28-618L	216-59L	18-412L	28-624L	216-412L	38-336L
18-59	28-618	216-59	18-412	28-624	216-412	38-336
18-69	28-718L	216-69	18-512L	28-724L	216-512L	38-436L
18-79L	28-718	216-79L	18-512	28-724	216-512	38-436
18-79	28-818	216-79	18-612	28-824	216-612	38-536
18-89	28-918	216-89	18-712	28-924	216-712	38-636
18-99		216-99	18-812		216-812	38-736
			18-912		216-912	38-836
18-511L	28-521L	216-511L				38-936
18-511	28-521	216-511				
18-611L	28-621L	216-611L	18-214L	28-428L	216-214L	38-442L
18-611	28-621	216-611	18-214	28-428	216-214	38-442
18-711L	28-721L	216-711L	18-314L	28-528L	216-314L	38-542L
18-711	28-721	216-711	18-314	28-528	216-314	38-542
18-811	28-821	216-811	18-414L	28-628	216-414L	38-642L
18-911	28-921	216-911	18-414	28-728	216-414	38-642
			18-514	28-828L	216-514	38-742
			18-614	28-828	216-614	38-842
			18-714	28-928	216-714	38-942
			18-814		216-814	
			18-914		216-914	

3.0 meter Nominal Width Units

110-112L	210-124L	220-112L	310-136L	420-124
110-112	210-124	220-112	310-136	420-224L
110-212L	210-224L	220-212L	310-236L	420-224
110-212	210-224	220-212	310-236	420-324
110-312	210-324	220-312	310-336	420-424
110-412	210-424	220-412	310-436	420-524
110-512	210-524	220-512	310-536	420-624L
110-612L	210-624L	220-612L	310-636L	420-624
110-612	210-624	220-612	310-636	420-724
110-712	210-724	220-712	310-736	420-824
110-812	210-824	220-812	310-836	420-924
110-912	210-924	220-912	310-936	
110-118L	210-136L	220-118L	310-154L	420-136L
110-118	210-136	220-118	310-154	420-136
110-218L	210-236L	220-218L	310-254L	420-236L
110-218	210-236	220-218	310-254	420-236
110-318L	210-336L	220-318L	310-354L	420-336L
110-318	210-336	220-318	310-354	420-336
110-418	210-436	220-418	310-454	420-436
110-518	210-536	220-518	310-554	420-536
110-618	210-636	220-618	310-654	420-636
110-718	210-736	220-718	310-754	420-736
110-818	210-836	220-818	310-854	420-836
110-918	210-936	220-918	310-954	420-936

See Footnotes for Additional Information

Johnson Controls Air Conditioning and Refrigeration Fze.
York AT Line of CTI Certified Cooling Towers
CTI Certification Validation Number 99-13-01
July 15, 2011 (Revision 11)

Footnotes:

1. AT, USS, UAT, and UT are prefixes to be added to the basic numeric model designations listed above to indicate the tower construction materials, generic configuration or options.
 - AT is used for units with standard galvanized materials and fabrication methods.
 - USS or UAT are used to indicate units with stainless steel materials for corrosion resistance.
 - UT is used to indicate units with super low sound fans.
 - ATF is used to indicate units with fiberglass materials for corrosion resistance.
2. Certification includes use of side, end, or bottom water inlet configuration.
3. Certification includes units with optional gear drive in place of standard belt drive.
4. Certification includes use of optional water silencers.
5. Certification includes use of optional external platforms/ladders for access.
6. Certification includes an optional supplier for fans on standard models and two optional low sound fan types one of which requires a 3.5% reduction in thermal capacity.
7. Certification includes use of an optional fan screen on all models requiring CE marking which results in a 2% reduction in thermal capacity.
8. Certification includes the use of an alternate wet heat transfer media on all models which results in a 10% reduction in thermal capacity.