



# COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068  
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

**Aggreko Cooling Tower Services**  
**AG Series CTI Certified Cooling Towers**  
**CTI Certification Validation Number C34A-08R02**  
**December 14, 2015 (Revision 2)**

Film Fill 7.5 HP/Fan Models

AG-4

AG-6

AG-8

AG-10

AG-12

Splash Fill 7.5 HP/Fan Models

AG-4-HD

AG-6-HD

AG-8-HD

AG-10-HD

AG-12-HD

**Footnotes:**

1. Models listed above have standard base inlet height of 8 feet.
2. Multi-cell combinations of the primary single-cell models are available but not individually listed (see example model number, below). Multi-cell models may require an increased base height and/or a capacity correction may apply. Please consult with the manufacturer for recommended base height for a specific application.
3. Certification includes two, approved, fan alternates, with no impact on rated capacity of the certified models.
4. Example model number: AG-10-HD  
AG = Line Designation  
-10 = 10 fans (75 HP total rated fan power per cell)  
-HD = Fill Type (blank=film fill; HD=splash fill)