

Masstec Link Co., Ltd.
Valor Series Line of CTI Certified Cooling Towers
CTI Certification Validation Number 05-28-01
January 4, 2008 (Revision 1)

Standard Fan Standard Stack	Standard Fan Extended Stack	Low Noise Fan Standard Stack
VNT-80 VNT-100	VNT-80S VNT-100S	VNT-70UL VNT-80UL
VNT-125 VNT-150	VNT-125S VNT-150S	VNT-100UL VNT-125UL
VNT-175 VNT-200	VNT-175S VNT-200S	VNT-150UL VNT-175UL
VNT-225 VNT-250	VNT-225S VNT-250S	VNT-200UL VNT-225UL
VNT-300	VNT-300S	VNT-250UL

Footnotes:

1. Certification includes tower construction materials indicated by the suffixes -B, -E, and -S which are added to basic model numbers above.
 - B is for FRP casing, FRP basin and HDG mainframe and hardware.
 - E is for FRP casing, FRP basin and stainless steel mainframe and hardware
 - S is for stainless steel casing, basin, mainframe and hardware.
2. The basic model numbers above are for 50hz fan motor and the suffix /F is added for 60hz motor applications. For example, VNT-100S-B is for 50hz motor, VNT-100S-B/F is for 60hz motor.
3. Certification includes use of side, end, or bottom water inlet configuration.
4. Certification includes units with optional gear drive in place of standard belt drive.
5. Certification includes use of optional handrail and/or ladder cage.
6. Multiple cell models of the single cell models above are also available but not listed.